



Timber post and struts and finishes (structural timber members and cladding)

- Timber to be of balao dry kiln with relevant certificate and documentary evidence whether structural or cladding finish.
- All timber item which shall be identified and replaced as per engineer's specification and methodology. Photographic evidence shall be taken by the contractor prior to replacement.
- Items to be quantified and agreed with the quantity surveyor
- proper measurement shall be taken on site by the contractor prior to manufacture/ replacement of damaged pieces.
- All visible timber shall have similar finish adapted to interior and exterior conditions. (primed and painted to architect's approval)
- glazing to openings shall be laminated with similar thickness
- external timber slats to be replaced with that of similar dimensions.
- internal wall cladding to be 12mm thick plywood primed and painted with two coats, colour as per existing

PROPOSED GROUND FLOOR LAYOUT

Project	
REFURBISHMENT WORKS AT SSR MEMORIAL MUSEUM SSR STREET PORT-LOUIS	
Title	
PROPOSED GROUND FLOOR LAYOUT (Sheet 2)	
Project Coordinator	R. Canhyee
Architect/S.Architect	J. Rojoa
Engineer/S.Engineer	R. Harah
Electrical/S.Elect.Eng.	S. Boodoo
Quantity Surveyor	H. Rambhojun
Technical Officer	R. Ramsurrun
Tech. Desn. Officer	Y.P. Vythelingum
Scale: 1 : 50	Date: 02.02.2022
MINISTRY OF NATIONAL INFRASTRUCTURE & COMMUNITY DEVELOPMENT PHENIX	Comp. No. S
DRG. No. RFW/04	Revision