



2. MINIMUM CONCRETE COVER TO REINFORCEMENT = 80mm
 3. MINIMUM LAP LENGTH TO BE = 45 X SMALLER BAR DIAMETER UNLESS OTHERWISE NOTED.
 4. DETAILING AND ABBREVIATIONS IN ACCORDANCE WITH SABS 0104.
 5. FOR STEEL SPECIFICATIONS AND BENDING DETAILS REFER BENDING SCHEDULE.
 6. REFERENCE DRAWINGS:
LAYOUT PLAN AND TYPICAL SETTINGS 301-00825/01-153
- ABBREVIATIONS:
- | | |
|-----|---------------------------|
| B1 | = LOWER BOTTOM STEEL |
| B2 | = UPPER BOTTOM STEEL |
| T1 | = UPPER TOP STEEL |
| T2 | = LOWER TOP STEEL |
| IF | = INSIDE FACE |
| OF | = OUTSIDE FACE |
| EF | = EACH FACE |
| EW | = EACH WAY |
| ALT | = ALTERNATE |
| ABR | = ALTERNATE BARS REVERSED |

This drawing, was prepared by Knight Pésold Consulting (Pty) Ltd based on the best information available at the time of preparation. During construction site conditions, or site conditions, or site development, may possibly dictate that amendments or adaptations be made to certain details on the drawing. Strict compliance with the project specifications is also essential. Knight Pésold Consulting (Pty) Ltd will therefore not accept liability for any losses, damages or consequential losses, suffered by any party resulting from the use or implementation of the contents of this drawing, if executed or amended without fulltime supervision by Knight Pésold Consulting (Pty) Ltd.

[illegible]

FOR CONSTRUCTION