

PANDANKUDI PANCHAYAT IN KOHOMPATTY UNION
SUMP NEAR PUMP ROOM TO PANDANKUDI 0.6LL SR

TO TRICHY


NHAI ROAD

63 PVC 4KSC

100M
58/63

TO SINGAMPUNARI

30M



PROPOSED SUMP
NEAR PUMP ROOM

AND BATH TANK
CAP : 0.05LL (PRO)

GL : 164.055

FVL : 163.060

MWL : 165.060

LPM: 58/63

P' SET : 1.00HP 58LPM X 17M H

50M



PANDANKUDI

CAP: 0.6LL OHT (EXI)

GL : 164.875

MWL : 175.380

LPM: 58/63