

FGMO- Delhi, Unit No. 602-A, Tower – 2, Sixth Floor, Konnectus, Bhavbhuti Marg, Opp. New Delhi Railway station,
Ajmeri Gate Side, New Delhi – 110001 Phone No- 011-23215011, 23218541

NOTICE INVITING TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING & MAINTENANCE OF AIR CONDITIONING SYSTEM AT KONNECTUS TOWER, NEW DELHI

CORRIGENDUM 01

- Point 01 of price bid “ The manufacturer of ODU and compressor shall be same” is replaced with “the make of compressor shall be as per OEM specification confirming to relevant Codes in vogue”
- Point 01 of price bid “ corrosion resistance ocean black fin coating” is replaced with “corrosion resistance ocean black fin coating or equivalent confirming to relevant Codes in vogue”
- Point 01 “no derating of cooling capacity at 39 degree centigrade” is replaced to “no derating of cooling capacity at 43 degree centigrade / ISHRAE design criteria for Delhi)
- Point 1b – Ai “ Round 360 deg cassette AC type indoor unit - 3.0 TR with panel” is replaced with “ 4 way cassette type indoor unit – 3 TR”

All other terms & conditions shall be same as mentioned in the tender document